

Fire Alarm System Plan Review Submittal Instructions

The Idaho State Fire Marshal's Office provides plan reviews for fire alarm systems and building construction at no cost to the building owner, contractor or authority having jurisdiction.

Fire Alarm Systems for State owned buildings

- The contractor must submit plans electronically either by e-mail or disk. Submittal must include information identified in IFC section 907.1.2 and NFPA 72, 7.4.4 through 7.4.10
- Plans must be scaled to 1/8 inch.
- Upon completion, plans will be stamped accordingly. The contractor will be contacted by telephone or e-mail with instructions.

Fire Alarm Systems for other buildings (NOT STATE OWNED)

- The fire alarm contractor MUST first contact the local fire jurisdiction.
- ONLY at the request of the local jurisdiction will plans be accepted for review. (See Idaho Code 41-257)
- The contractor must submit plans electronically either by e-mail or disk. Submittal must include information identified in IFC section 907.1.2 and NFPA 72, 7.4.4 through 7.4.10
- Plans must be scaled to 1/8 inch.
- Upon completion, plans will be forwarded to the local jurisdiction for acceptance.

****THIS OFFICE WILL NOT STAMP ACCEPTED PLANS. RECOMMENDATIONS WILL ONLY BE GIVEN TO THE LOCAL AHJ FOR THEIR ACCEPTANCE****